



Insertion Loss (IL)

+ : "forward flow" where noise & airflow move in same direction (e.g. supply side)
- : "reverse flow" where noise & airflow move in opposite directions (e.g. return side)

A (in.)	Centerbody Diameter* (in.)	D (in.)	Fan Inlet/Outlet Velocity (ft. per min.)	OCTAVE BAND - Hz/D.I.L. (dB)							
				63	125	250	500	1000	2000	4000	8000
54	0	54	- 2000	2	3	9	13	9	7	6	4
			0	2	3	9	12	8	7	6	4
			+ 2000	2	3	9	12	9	7	6	4
54	0	108	- 2000	2	6	13	21	18	11	9	9
			0	2	6	13	20	17	10	9	8
			+ 2000	2	6	13	20	17	11	10	8
54	16	54	- 2000	2	4	9	14	15	9	9	7
			0	2	4	9	13	14	9	9	7
			+ 2000	2	4	8	12	13	9	9	7
54	16	108	- 2000	3	7	15	22	21	15	13	11
			0	3	6	14	21	20	14	13	11
			+ 2000	3	6	14	21	20	14	13	11
54	20	54	- 2000	3	4	10	17	19	13	11	9
			0	3	4	9	16	18	13	11	9
			+ 2000	3	4	9	15	17	13	11	9
54	20	108	- 2000	4	7	19	24	26	19	16	12
			0	3	7	18	23	25	18	16	12
			+ 2000	3	7	18	23	25	18	17	13
54	26	54	- 2000	4	5	12	20	22	18	14	12
			0	3	5	11	19	22	18	14	12
			+ 2000	3	5	10	18	21	18	15	11
54	26	108	- 2000	5	9	22	27	33	25	19	16
			0	4	8	21	26	32	24	19	16
			+ 2000	4	8	20	26	32	24	20	17

*Note: The centerbody diameter should be matched to the fan hub diameter for an inlet silencer or the fan motor diameter for a discharge silencer.

Pressure Drop (PD)

A (in.)	B (in.)	C (in.)	Centerbody Diameter. (in.)	D (in.)	Weight	Pressure Drop based on Fan Inlet/Outlet Velocity = 2000 FPM*			
						Silencer On:			
						Fan Inlet		Fan Outlet	
Ducted		Unducted		Ducted		Unducted			
54	68	74	0	54	710	0.03	0.05	0.03	0.13
54	68	74	0	108	1215	0.04	0.06	0.03	0.13
54	68	74	16	54	870	0.04	0.06	0.03	0.14
54	68	74	16	108	1415	0.04	0.07	0.03	0.14
54	68	74	20	54	905	0.03	0.05	0.05	0.17
54	68	74	20	108	1465	0.04	0.06	0.05	0.17
54	68	74	26	54	970	0.04	0.07	0.05	0.19
54	68	74	26	108	1555	0.05	0.08	0.05	0.19

*Note: For Pressure Drops at other velocities:

$$\text{Actual PD} = \left(\frac{\text{Actual velocity}}{2000 \text{ FPM}} \right)^2 \times \text{PD from chart}$$