



Insertion Loss (IL)

+ : "forward flow" where noise & airflow move in same direction (e.g. supply side)
 - : "reverse flow" where noise & airflow move in opposite directions (e.g. return side)

A (in.)	Centerbody Diameter* (in.)	D (in.)	Fan Inlet/Outlet Velocity (ft. per min.)	OCTAVE BAND - Hz/D.I.L. (dB)							
				63	125	250	500	1000	2000	4000	8000
78	0	78	- 2000	2	5	8	13	8	7	6	4
			0	2	5	8	12	8	7	6	4
			+ 2000	2	5	7	12	8	7	6	4
78	0	117	- 2000	3	8	10	20	17	12	9	8
			0	3	8	10	19	16	12	9	8
			+ 2000	3	8	9	19	16	12	10	8
78	20	78	- 2000	2	6	10	14	14	12	9	7
			0	2	5	9	13	13	12	9	7
			+ 2000	2	5	8	12	12	12	9	7
78	20	117	- 2000	5	9	14	21	19	16	13	10
			0	5	9	13	20	18	15	13	10
			+ 2000	4	9	13	20	18	15	13	10
78	26	78	- 2000	3	6	11	16	17	14	10	9
			0	3	5	10	15	16	14	10	9
			+ 2000	3	5	10	14	15	14	10	9
78	26	117	- 2000	6	11	16	23	24	19	16	11
			0	5	10	15	22	23	18	16	11
			+ 2000	5	10	15	22	23	18	17	11
78	30	78	- 2000	5	9	13	20	23	16	13	10
			0	4	8	12	19	23	16	13	10
			+ 2000	4	8	11	18	22	16	13	10
78	30	117	- 2000	6	13	18	26	26	21	17	11
			0	6	12	17	25	25	20	17	11
			+ 2000	6	12	17	24	25	20	17	11

*Note: The centerbody diameter should be matched to the fan hub diameter for an inlet silencer or the fan motor diameter for a discharge silencer.

Pressure Drop (PD)

A (in.)	B (in.)	C (in.)	Centerbody Diameter. (in.)	D (in.)	Weight	Pressure Drop based on Fan Inlet/Outlet Velocity = 2000 FPM*			
						Silencer On:			
						Fan Inlet		Fan Outlet	
Ducted		Unducted		Ducted		Unducted			
78	98	104	0	78	1560	0.03	0.05	0.03	0.13
78	98	104	0	117	2125	0.04	0.06	0.03	0.13
78	98	104	20	78	1845	0.03	0.05	0.04	0.15
78	98	104	20	117	1255	0.04	0.06	0.04	0.15
78	98	104	26	78	1920	0.04	0.06	0.06	0.18
78	98	104	26	117	2545	0.04	0.07	0.06	0.18
78	98	104	30	78	1975	0.04	0.06	0.06	0.18
78	98	104	30	117	2620	0.04	0.07	0.06	0.18

*Note: For Pressure Drops at other velocities:

$$\text{Actual PD} = \left(\frac{\text{Actual velocity}}{2000 \text{ FPM}} \right)^2 \times \text{PD from chart}$$